

# PRODUCT SUBMITTAL INFORMATION

---

## THERMAL GROUT, PART II (Silica Compound)



August 2011

**THERMAL GROUT, PART II** is a silica compound material that shall have the following minimum specifications when supplied by GeoPro, Inc.

The compound shall be washed, dried, pre-packaged silica sand compound which is graded and shall have an AFS GFN between 40-60 for Thermal Grout Lite and 60-80 for Thermal Grout Select. Additionally, GeoPro recommends that less than 5% of a given sand distribution be larger than a 40-Mesh for Thermal Grout Select and no more than 2.5% passing a 200-Mesh.

Sincerely,

A handwritten signature in black ink, appearing to read "Ryan Carda".

Ryan Carda, Lead Support Engineer  
**GeoPro, Inc.**